



Account No : 122451

Date : 15-March-2002

Supplementary report prepared by Water Treatment Unit

Component Name	Unfiltered Water	Filtered Water	Unit	% Reduction
General Data				
Chlorine	2.5	< 0.1	mg/L	>99.9
Suspended Solids	47	1	mg/L	>97
Nutrients				
Nitrate as nitrogen	44.5	0.001	mg/L	>99.9
Metals				
Arsenic	0.046	<0.001	mg/L	>97.8
Copper	3.041	<0.001	mg/L	>99.9
Lead	0.9690	<0.0005	mg/L	>99.9
Mercury	1.5540	<0.0005	mg/L	>99.9
Disinfection By Products				
Total trihalomethane	6010	<4	ug/L	>99.9
Chloroform	2490	<1	ug/L	>99.9
Bromodichloromethane	2850	<1	ug/L	>99.9
Bromoform	670	<1	ug/L	>99.8
Pesticides				
Lindane	2.46	<0.05	ug/L	>98.0

Sandy Brinkmann

Water Treatment Unit
 Australian Water Quality Centre
 Private Mail Bag 3
 Salisbury S.A. 5108